

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil	0	5
sandy clay loam	5	20
gray clay	20	60
clay & gravel	60	105
limerock	105	220

Total Depth **220**

Casing: 5" STEEL from 0' to 108'

Grout: BENSEAL from 0 to 40

Water from rock at 108' to 220'

Static level 70' below casing top which is 1' above GL

Pumping level 90' when pumping at 20 gpm for 4 hr(s)

Permanent pump installed at 160' on 7/10/2000, with a capacity of 20 gpm

Remarks: driller's est. well yield 25-35 gpm

Owner Address: 915 Winthrop Rockford, IL

Address of well: 2141 Merrick Dr. Belvidere, IL Belvidere IL

Add'l loc info: Lot: 11 Subdivision: Aberdeen East

Location source: Aerial Photograph verified

Verified by: VJA on 5/4/2021

[Imaged Log viewing help: New users please read this.](#)

[GET FILE](#)

ISWS Document

Permit Date: March 7, 2000

Permit #: 007-028-00

COMPANY Hinkle, J & J Well & Septic

FARM Baker, James

DATE DRILLED May 17, 2000

NO.

ELEVATION 0'

COUNTY NO. 23526

LOCATION

LATITUDE 42.324086

LONGITUDE -88.896155

COUNTY Boone

API# 1200723526 00

4-44N-3E