

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil	0	5
clay	5	40
clay & gravel	40	45
sandy clay	45	55
sand & gravel	55	67

Total Depth

67

Casing: 5" STEEL from 0' to 63'

5" STAINLESS STL SCREEN from 63' to 67'

Screen: 4' of 5" diameter 15 slot

Water from drift at 60' to 67'

Static level 40' below casing top which is 1' above GL

Pumping level 45' when pumping at 10 gpm for 4 hr(s)

Permanent pump installed at 50' on 7/25/2000, with a capacity of 10 gpm

Remarks: driller's est. well yield 20 gpm

Owner Address: 1700 N. Alpine Rockford, IL

Address of well: 615 Waco Way Belvidere, IL Belvidere IL

Add'l loc info: Lot: 111 Subdivision: Belair

Location source: Aerial Photograph verified

Verified by: VJA on 4/28/2021

[Imaged Log viewing help: New users please read this.](#)

[GET FILE](#)

ISWS Document

Permit Date: July 11, 2000

Permit #: 007-080-00

COMPANY Hinkle, J & J Well & Septic

FARM Prairie Homes

DATE DRILLED July 18, 2000

NO.

ELEVATION 0'

COUNTY NO. 23552

LOCATION

LATITUDE 42.314838

LONGITUDE -88.835264

COUNTY Boone

API# 1200723552 00

1-44N-3E