

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil	0	5
clay	5	35
gray clay	35	60
sand clay	60	90
white rock	90	115
yellow rock	115	145
brown rock	145	200
gray rock	200	245

Total Depth

245

Casing: 5" ASTM A53B from 0' to 97'

Grout: BENTONITE from 0 to 97

Water from brown rock at 140' to 245'

Static level 40' below casing top which is 1' above GL

Pumping level 45' when pumping at 10 gpm for 6 hr(s)

Permanent pump installed at 109' on 5/5/2002, with a capacity of 10 gpm

Remarks: driller's est. well yield 60 gpm

Owner Address: 1306 Bergstom Rd. Rockford, IL

Address of well: 3333 Prairie Rd. Timberlane, IL Timberlane IL

Add'l loc info: Lot: 4 Subdivision: Prairie Lane

Location source: Aerial Photograph verified

Verified by: VJA on 3/1/2021

[Imaged Log viewing help: New users please read this.](#)

[GET FILE](#)

ISWS Document

Permit Date: December 18, 2001 **Permit #:** 007-165-01

COMPANY Bull, Jack Well & Septic

FARM Adams, John

DATE DRILLED May 4, 2002

NO.

ELEVATION 0'

COUNTY NO. 23819

LOCATION

LATITUDE 42.339206

LONGITUDE -88.872439

COUNTY Boone

API# 1200723819 00

34-45N-3E