

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil	0	2
clay - lost log & formations	2	245
Dolomite	245	282

Total Depth **282**

Casing: 6" ASTM A 53B from -1' to 118'

Grout: BENSEAL from 0 to 118

Water from Dolomite at 245' to 282'

Static level 20' below casing top which is 1' above GL

Pumping level 20' when pumping at 10 gpm for 2 hr(s)

Permanent pump installed at 80' on 5/14/2016, with a capacity of 10 gpm

Remarks: Driller's Estimated Well Yield 30 gpm

Owner Address: 3968 Hunter Rd. Poplar Grove, IL

Address of well: same as above

Location source: Global Positioning System verified

Verified by: VJA on 3/16/2021

Permit Date: January 29, 2016

Permit #: 007-004-16

COMPANY Beaman, John A.

FARM Christiansen, Melton

DATE DRILLED May 11, 2016

NO.

ELEVATION '

COUNTY NO. 24756

LOCATION

LATITUDE 42.429417

LONGITUDE -88.861083

COUNTY Boone

API# 1200724756 00

27-46N-3E