

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
yellow clay	0	21
gravel	21	23
gray clay	23	30
dark gray with stones & gravel	30	45
pink clay	45	63
gray gravel	63	69
pink clay	69	73
dark gray clay	73	77
black clay peat	77	82
wood silty sand clay	82	100
fine sand - Sankoty	100	122
30-40 slot sand - Sankoty	122	135
fine sand - Sankoty	135	137

Total Depth **137**

Casing: 4" PVC #40 from -1' to 131'

Screen: 4' of 4" diameter 15 slot

Grout: BENT CLAY SLRY from 0 to 20

Water from Sankoty at 131' to 135'

Static level 103' below casing top which is 1' above GL

Pumping level 105' when pumping at 30 gpm for 2 hr(s)

Permanent pump installed at 0' on , with a capacity of 0 gpm

Remarks: Will finish hook up after house is built

Owner Address: R. #1 74-A Box #160 Granville, IL

Address of well: R. #4 at Pilgrim Park Princeton, IL Princeton IL

Location source: Location from permit

Verified by: VJA on 4/25/2023

Permit Date: January 9, 1998

Permit #: 011-002-98

COMPANY Lutes, George W.

FARM Welch, Patricia

DATE DRILLED June 23, 1998

NO.

ELEVATION 0'

COUNTY NO. 22473

LOCATION

LATITUDE 41.339363

LONGITUDE -89.343493

COUNTY Bureau

API# 1201122473 00

28-16N-10E