

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
gray clay	0	45
gray fine sand	45	90
gray clay	90	145
gray fine to medium sand	145	205

Total Depth **205**

Casing: 10" PVC from -1' to 175'

10" PVC SCREEN from 175' to 205'

Screen: 30' of 10" diameter 0.025 slot

Grout: BENTONITE from 0 to 175

Water from sand at 145' to 205'

Static level 80' below casing top which is 1' above GL

Pumping level 140' when pumping at 700 gpm for 1 hr(s)

Permanent pump installed at 136' on 8/20/2012, with a capacity of 600 gpm

Remarks: Driller's Estimated Well Yield 700 gpm

Owner Address: 15722 645 E. St. Sheffield, IL

Address of well: 1640 N & 645 E Sheffield, IL Sheffield IL

Location source: Location from permit

Verified by: VJA on 4/6/2023

[Imaged Log viewing help: New users please read this.](#)

GET FILE	ISWS Document
GET FILE	ISWS Document
GET FILE	ISWS Document

Permit Date: July 31, 2012

Permit #: 011-039-12

COMPANY Haskins, D.

FARM Draper Family Trust

DATE DRILLED August 1, 2012

NO.

ELEVATION '

COUNTY NO. 23454

LOCATION

LATITUDE 41.384574

LONGITUDE -89.722292

COUNTY Bureau

API# 1201123454 00

8-16N-7E