

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	7
fine sand	7	64
clay	64	83
fine sand	83	130
fine medium sand	130	180

Total Depth **180**

Casing: 10" PVC from -1' to 140'

10" SCREEN from 140' to 150'

Screen: 40' of 10" diameter 0.025 slot

Grout: BENTONITE from 0 to 65

Water from sand at 130' to 180'

Static level 80' below casing top which is 1' above GL

Pumping level 60' when pumping at 1000 gpm for 1 hr(s)

Permanent pump installed at 80' on 4/6/2015, with a capacity of 800 gpm

Remarks: Driller's Estimated Well Yield 1000 gpm

Owner Address: 27555 425 E. St. Tampico, IL

Address of well: 300 E. St & Rte. 92 Yorktown, IL Yorktown IL

Location source: Global Positioning System verified

Verified by: VJA on 3/6/2023

Permit Date: December 9, 2014

Permit #: 011-035-14

COMPANY Latta, Kirk Stephen

FARM Kelly, Mike

DATE DRILLED December 9, 2014

NO.

ELEVATION '

COUNTY NO. 23568

LOCATION

LATITUDE 41.565667

LONGITUDE -89.797056

COUNTY Bureau

API# 1201123568 00

10-18N-6E