

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
black loam	0	30
red loam	30	40
sand & gravel	40	75

Total Depth

75

Casing: 16" PVC SCREEN from 35' to 75'

Screen: 40' of 16" diameter 30 slot

Grout: BENTONITE from 10 to 23

PEA GRAVEL from 23 to 75

Water from sand & gravel at 30' to 75'

Static level 15' below casing top which is 1' above GL

Remarks: Driller's Estimated Well Yield 600 gpm

Owner Address: 604 Pulliam St. Hardin, IL

in a field

Location source: Global Positioning System verified

[Imaged Log viewing help: New users please read this.](#)

[GET FILE](#)

ISWS Document

Permit Date: May 11, 2012

Permit #: 013-01-2012

COMPANY Swan, Karl F.

FARM Gillespe, John & Wheeler, Keith

DATE DRILLED May 12, 2012

NO. 3

ELEVATION 426' GL

COUNTY NO. 20389

LOCATION

LATITUDE 39.224808

LONGITUDE -90.616022

COUNTY Calhoun

API# 1201320389 00

2-10S-2W