

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
top soil	0	1
broken lime chips & brown clay	1	8
yellow clay	8	12
soft clay, sand & lime chips	12	30
buff limestone	30	50
gray limestone	50	85
Maquoketa shale	85	215
limestone	215	220

Total Depth

220

Casing: 6" 18.97#/FT .280 WALL from -2' to 104'

Grout: NEAT CEMENT from 8 to 104

Size hole below casing: 6"

Static level 54' below casing top which is 2' above GL

Pumping level 90' when pumping at 0 gpm for 2 hr(s)

Permanent pump installed at 130' on 8/5/1994, with a capacity of 10 gpm

Owner Address: 327 6th Street Monroe, WI

Address of well: Lakeview Drive Lake Carroll, IL Lake Carroll IL

Add'l loc info: Lot: 69 Subdivision: Lake Carroll
Sec. 17

Location source: Location from permit

Permit Date: July 19, 1994

Permit #: 024096

COMPANY Niffenegger, Edward L.

FARM Brewer, George

DATE DRILLED July 28, 1994

NO.

ELEVATION 0'

COUNTY NO. 21055

LOCATION

LATITUDE 42.173226

LONGITUDE -89.892479

COUNTY Carroll

API# 1201521055 00

11-25N-5E