

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
top soil	0	2
red clay	2	19
yellow limestone	19	76
blue shale	76	229
gray limestone	229	360

Total Depth

360

Casing: 6" ASTM A 53B STEEL from 2' to 102'

Grout: BENTONITE from 0 to 102

Water from shale/limestone at 103' to 360'

Static level 103' below casing top which is 2' above GL

Pumping level 280' when pumping at 15 gpm for 1 hr(s)

Permanent pump installed at 280' on 2/12/2024, with a capacity of 10 gpm

Remarks: Driller's Estimated Well Yield 20 gpm

Owner Address: 28-45 Southview Dr Lanark, IL

Address of well: same as above

Location source: Global Positioning System verified

Permit Date: November 27, 2023

Permit #: 015-23-2023

COMPANY Thompson, John

FARM Claycomb, Javi

DATE DRILLED December 6, 2023

NO.

ELEVATION 810' GL

COUNTY NO. 22144

LOCATION

LATITUDE 42.186111

LONGITUDE -89.885833

COUNTY Carroll

API# 1201522144 00

2-25N-5E