

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay and gravel	0	90
gray sandy clay	90	205
gray clay and gravel	205	220
sand and gravel	220	260
gray clay at	260	260

Total Depth **260**

Casing: 10" STEEL 3/8" WALL from 0' to 240'
 10" S/S WELL SCREEN from 240' to 260'

Screen: 20' of 10" diameter 0.06 slot

Water from drift at 240' to 260'

Static level 41' below casing top which is 0' above GL

Pumping level 46' when pumping at 300 gpm for 24 hr(s)

Permanent pump installed at 0' on , with a capacity of 0 gpm

Driller's Log filed.

Sample set # 63877 0' - 280' Received: 6/28/1983

Owner Address: Village Building Fisher, IL

Location source: Location from permit

Permit Date: June 18, 1979 **Permit #:** 87901

COMPANY Miller, J.P. Artesian Well Co.

FARM Fisher, Village of

DATE DRILLED July 29, 1979 **NO.** 4

ELEVATION 0' **COUNTY NO.** 22527

LOCATION 2500'S line, 980'E line of SE

LATITUDE 40.317637 **LONGITUDE** -88.350362

COUNTY Champaign **API#** 1201922527 00 **36-22N-7E**