

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
top soil	0	2
yellow clay	2	16
grey clay	16	94
sand	94	106
green clay	106	180
sand	180	212

Total Depth **212**

Casing: 4" PVC from 0' to 208'

Screen: 4' of 4" diameter 12 slot

Grout: CEMENT from 4 to 40

Size hole below casing: 4"

Water from sand at 180' to 212'

Static level 61' below casing top which is 0' above GL

Pumping level 70' when pumping at 40 gpm for 2 hr(s)

Permanent pump installed at 100' on , with a capacity of 10 gpm

Owner Address: Rt. 1 Seymour, IL

Location source: Location from permit

[Imaged Log viewing help: New users please read this.](#)

GET FILE

ISWS Document

Permit Date: May 1, 1985

Permit #: 117551

COMPANY Eaton, Zane C.

FARM Morgan, Joe

DATE DRILLED May 6, 1985

NO.

ELEVATION 0'

COUNTY NO. 22786

LOCATION 400'S line, 500'W line of

LATITUDE 40.157738

LONGITUDE -88.443897

COUNTY Champaign

API# 1201922786 00

29-20N-7E