

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
top soil/fill	0	2
yellow clay	2	9
brown peat/soil zone	9	10
brown clay	10	12
gray clay, w/sand streak @60'	12	78
silty fine gray sand	78	88
gray clay	88	91
dirty fine gray sand	91	97
gravelly gry clay w/sand strks @114,129'	97	139
silty dirty fine gray sand	139	148
silty fine/med gray sand	148	159

Total Depth **159**

Casing: 5" SDR 21 PVC from 0' to 151'

Screen: 8' of 5" diameter 10 slot

Grout: SLURRY from 0 to 0

Water from sand at 148' to 159'

Static level 65' below casing top which is 1' above GL

Pumping level 0' when pumping at 30 gpm for 0 hr(s)

Owner Address: 1001 N. Highcross Rd. Urbana, IL

Location source: Location from permit

Permit Date: September 26, 1995 **Permit #:**

COMPANY Sims, Ronald M. Jr.

FARM Holte, Bjorg

DATE DRILLED October 12, 1995 **NO.** 2

ELEVATION 0' **COUNTY NO.** 24803

LOCATION

LATITUDE 40.121372 **LONGITUDE** -88.163874

COUNTY Champaign **API#** 1201924803 00 **10-19N-9E**