

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
top soil	0	1
brown clay	1	13
gray clay	13	20
sand & gravel	20	23
gravelly gray clay	23	27
inter/sand streaks/gray clay	27	36
gravelly gray clay	36	64
yellow sand & gravel	64	74
inter/gray clay/brown sand	74	82
gray sand & gravel	82	84
inter/gray clay/gray sand	84	96
gravelly gray clay	96	119
inter/gray clay/sand streaks	119	125
silty fine to medium gray sand	125	131

Total Depth

131

Casing: 5" SDR 21 PVC from 0' to 127'

Screen: 4' of 5" diameter 10 slot

Grout: SLURRY from 0 to 0

Water from sand at 125' to 131'

Static level 40' below casing top which is 1' above GL

Pumping level 0' when pumping at 8 gpm for 1 hr(s)

Owner Address: 4312 E. Airport Rd. Urbana, IL

Location source: Location from permit

Permit Date: October 3, 1995

Permit #:

COMPANY Sims, Ronald M. Jr.

FARM Rogowski, Gregory

DATE DRILLED October 10, 1995

NO. 1

ELEVATION 0'

COUNTY NO. 24805

LOCATION

LATITUDE 40.143051

LONGITUDE -88.145286

COUNTY Champaign

API# 1201924805 00

35-20N-9E