

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
yellow clay	0	13
gray clay	13	90
fine sand	90	130
gravel	130	138

Total Depth **138**

Casing: 5" PVC from 0' to 133'

4" STAINLESS STL SCREEN from 133' to 138'

Screen: 5' of 4" diameter 15 slot

Grout: BENTONITE from 0 to 63

Water from sand & gravel at 133' to 138'

Static level 20' below casing top which is 1' above GL

Pumping level ' when pumping at 90 gpm for 4 hr(s)

Remarks: Driller's Estimated Well Yield 90 gpm

Owner Address: 200 Buena Vista Dr. Champaign, IL

Address of well: 1749 B CR 1850 N Urbana, IL Urbana IL

Location source: Location from permit

[Imaged Log viewing help: New users please read this.](#)

[GET FILE](#)

ISWS Document

Permit Date: March 30, 2007

Permit #: 19-09-07

COMPANY York, Warren Thomas

FARM Pelfrey, Phillip

DATE DRILLED May 1, 2007

NO.

ELEVATION '

COUNTY NO. 26331

LOCATION

LATITUDE 40.144873

LONGITUDE -88.133294

COUNTY Champaign

API# 1201926331 00

36-20N-9E