

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
yellow clay	0	13
gray clay	13	79
fine sand	79	100
sand & gravel	100	110

Total Depth **110**

Casing: 5" PVC from 0' to 105'

4" SCREEN from 105' to 110'

Screen: 5' of 4" diameter 15 slot

Grout: BENTONITE from 0 to 65

Water from sand & gravel at 105' to 110'

Static level 15' below casing top which is ' above GL

Pumping level ' when pumping at 90 gpm for 3 hr(s)

Remarks: Driller's Est Yield 90 gpm, pond

Owner Address: 2061 CR 2100 N St Joseph, IL

Address of well: same as above

Location source: Location from permit

[Imaged Log viewing help: New users please read this.](#)

[GET FILE](#)

ISWS Document

Permit Date: August 6, 2007

Permit #: 019-40-07

COMPANY York, Warren Thomas

FARM White, Victor

DATE DRILLED August 15, 2007

NO.

ELEVATION '

COUNTY NO. 26367

LOCATION

LATITUDE 40.185398

LONGITUDE -88.075204

COUNTY Champaign

API# 1201926367 00

21-20N-10E