

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
timber soil	0	4
yellow clay	4	23
blue clay	23	40
coarse gray sand	40	55

Total Depth **55**

Casing: 5" PVC SDR 21 from -2' to 47'

3" STAINLESS STL SCREEN from 47' to 55'

Screen: 8' of 3" diameter 12 slot

Grout: BENTONITE from 0 to 45

Water from sand at 40' to 55'

Static level 13' below casing top which is 2' above GL

Pumping level 30' when pumping at 40 gpm for 2 hr(s)

Permanent pump installed at 34' on 11/28/2008, with a capacity of 22 gpm

Remarks: Driller's Estimated Well Yield 40 gpm

Owner Address: 149 CR 2300 N Mahomet, IL

Address of well: 2489 CR 550 E Dewey, IL Dewey IL

Location source: Location from permit

Imaged Log viewing help: New users please read this.

GET FILE

ISWS Document

Permit Date: November 10, 2008 **Permit #:** 019-72-08

COMPANY Kingsley, Arthur W.

FARM Dallas Construction % Doug Dallas

DATE DRILLED November 28, 2008 **NO.**

ELEVATION ' **COUNTY NO.** 26502

LOCATION

LATITUDE 40.236947 **LONGITUDE** -88.357026

COUNTY Champaign **API#** 1201926502 00 **36-21N-7E**