

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
timber soil	0	4
yellow clay	4	17
blue clay	17	89
gray sand	89	105

Total Depth **105**

Casing: 5" PVC SDR 21 from -2' to 91'

4" STAINLESS STL SCREEN from 91' to 95'

Screen: 4' of 4" diameter 12 slot

Grout: BENTONITE from 0 to 85

Water from sand at 89' to 105'

Static level 25' below casing top which is 2' above GL

Pumping level 85' when pumping at 18 gpm for 2 hr(s)

Permanent pump installed at 89' on 12/29/2008, with a capacity of 12 gpm

Remarks: Driller's Estimated Well Yield 18 gpm

Owner Address: PO Box 855 Mahomet, IL

Address of well: 2481-C 550 Dewey, IL Dewey IL

Add'l loc info: Subdivision: Summerfield

Location source: Location from permit

Imaged Log viewing help: New users please read this.

GET FILE

ISWS Document

Permit Date: November 10, 2008 **Permit #:** 019-73-08

COMPANY Kingsley, Arthur W.

FARM Classic Homes

DATE DRILLED December 29, 2008 **NO.**

ELEVATION ' **COUNTY NO.** 26526

LOCATION

LATITUDE 40.235128 **LONGITUDE** -88.357025

COUNTY Champaign **API#** 1201926526 00 **36-21N-7E**