

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
black clay	0	2
yellow clay	2	13
gray clay	13	61
gravel	61	64
gray clay	64	122
gravel	122	126
gray clay	126	194
fine sand & gray clay	194	212
gravel	212	240
gravel - coarse	240	268

Total Depth **268**

Casing: 5" SDR 21 from -1' to 139'
 5" SDR 17 from 139' to 259'
 5" STAINLESS STL SCREEN from 259' to 263'

Screen: 4' of 5" diameter 20 slot

Grout: EZ SEAL from 0 to 249
 MUSCATINE from 249 to 263

Water from gravel, gravel crs at 212' to 268'

Static level 106' below casing top which is 1' above GL

Pumping level ' when pumping at 40 gpm for hr(s)

Remarks: Driller's Estimated Well Yield 40 gpm

Owner Address: 476 Co Rd 1700 N Champaign, IL

Address of well: same as above

Location source: Location from permit

[Imaged Log viewing help: New users please read this.](#)

[GET FILE](#)

ISWS Document

Permit Date: March 25, 2009

Permit #: 019-14-09

COMPANY Vaughn, Kenneth G.

FARM Berbaum, Paul

DATE DRILLED April 1, 2009

NO. 1

ELEVATION '

COUNTY NO. 26552

LOCATION

LATITUDE 40.128438

LONGITUDE -88.373203

COUNTY Champaign

API# 1201926552 00

2-19N-7E

ILLINOIS STATE GEOLOGICAL SURVEY

Page 2

[GET FILE](#)

ISWS Document

Permit Date: March 25, 2009

Permit #: 019-14-09

COMPANY Vaughn, Kenneth G.

FARM Berbaum, Paul

DATE DRILLED April 1, 2009

NO. 1

ELEVATION '

COUNTY NO. 26552

LOCATION

LATITUDE 40.128438

LONGITUDE -88.373203

COUNTY Champaign

API# 1201926552 00

2-19N-7E