

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
black clay	0	3
yellow clay	3	9
yellow gravel	9	12
yellow clay	12	14
gray clay	14	125
gravel	125	145
gray clay	145	155
gravel	155	200
gravel - coarse	200	270

Total Depth **270**

Casing: 5" SDR 21 from -3' to 137'
 5" SDR 17 from 137' to 257'
 5" STAINLESS STL SCREEN from 257' to 261'

Screen: 4' of 5" diameter 20 slot

Grout: EZ SEAL from 0 to 247
 NATURALLY DEVELOPED from 247 to 261

Water from gravel - coarse at 155' to 270'

Static level 124' below casing top which is 3' above GL

Pumping level ' when pumping at 25 gpm for hr(s)

Remarks: Driller's Estimated Well Yield 25 gpm

Owner Address: 1837 CR 500 E Champaign, IL

Address of well: same as above

Location source: Location from permit

[Imaged Log viewing help: New users please read this.](#)

[GET FILE](#) ISWS Document

[GET FILE](#) ISWS Document

Permit Date: March 12, 2009

Permit #: 019-11-09

COMPANY Vaughn, Kenneth G.

FARM Parnell, Richard

DATE DRILLED March 20, 2009

NO. 1

ELEVATION '

COUNTY NO. 26625

LOCATION

LATITUDE 40.147250

LONGITUDE -88.370194

COUNTY Champaign

API# 1201926625 00

35-20N-7E