

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil	0	1
brown clay	1	10
gray clay	10	61
brown clay	61	70
gray clay	70	98
fine gray sand	98	103

Total Depth

103

Casing: 5" SDR 21/SCH 40 PVC from -1' to 99'

5" SCREEN from 99' to 103'

Screen: 4' of 5" diameter 10 slot

Grout: BENTONITE from 5 to 87

TORPEDO SAND from 98 to 103

Water from sand at 98' to 103'

Static level 36' below casing top which is 1' above GL

Pumping level ' when pumping at 20 gpm for 1 hr(s)

Remarks: Driller's Estimated Well Yield 20+ gpm

Owner Address: 1485 CR 1800 E Urbana, IL

Address of well: same as above

Location source: Global Positioning System verified

[Imaged Log viewing help: New users please read this.](#)

[GET FILE](#)

ISWS Document

Permit Date: August 28, 2013

Permit #: 19-45-13

COMPANY Sims, R. Marc Jr.

FARM Burnett, Andy

DATE DRILLED September 19, 2013

NO. 2

ELEVATION '

COUNTY NO. 27069

LOCATION

LATITUDE 40.096667

LONGITUDE -88.124667

COUNTY Champaign

API# 1201927069 00

24-19N-9E