

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil	0	1
brown clay	1	16
sandy gray clay	16	57
fine gray sand	57	66

Total Depth

66

Casing: 5" SDR 21 SCH 40 PVC from -1' to 62'
5" SCREEN from 62' to 66'

Screen: 4' of 5" diameter 10 slot

Grout: BENTONITE from 5 to 53
TORPEDO SAND from 61 to 66

Water from sand at 57' to 66'

Static level 32' below casing top which is 1' above GL

Pumping level ' when pumping at 10 gpm for 1 hr(s)

Remarks: Driller's Estimated Well Yield 10 gpm

Owner Address: 1878 CR 2100 N Urbana, IL

Address of well: same as above

Location source: Global Positioning System verified

[Imaged Log viewing help: New users please read this.](#)

[GET FILE](#)

ISWS Document

Permit Date: August 30, 2013

Permit #: 19-49-13

COMPANY Sims, R. Marc Jr.

FARM Laws, Jeff & Tonie

DATE DRILLED October 10, 2013

NO. 2

ELEVATION '

COUNTY NO. 27075

LOCATION

LATITUDE 40.181222

LONGITUDE -88.109111

COUNTY Champaign

API# 1201927075 00

18-20N-10E