

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
-------------------	------------	---------------

Total Depth	160
--------------------	------------

Casing: 5" SDR 21 from -2' to 154'

5" STAINLESS STL SCREEN from 154' to 160'

Screen: 6' of 5" diameter 20 slot

Grout: BENSEAL from 0 to 144

Water from sand at 154' to 160'

Static level 94' below casing top which is 2' above GL

Pumping level 112' when pumping at 30 gpm for hr(s)

Permanent pump installed at ' on , with a capacity of gpm

Remarks: pump install spring of 2014

Owner Address: 2200 South Philo Rd Urbana, IL

Address of well: same as above

Location source: Location from permit

[Imaged Log viewing help: New users please read this.](#)

[GET FILE](#)

ISWS Document

Permit Date: April 11, 2013

Permit #: 19-06-13

COMPANY Sims, R. Marc Jr.

FARM St Mathew Luthern Church

DATE DRILLED November 22, 2013

NO. 1

ELEVATION '

COUNTY NO. 27511

LOCATION

LATITUDE 40.095729

LONGITUDE -88.185105

COUNTY Champaign

API# 1201927511 00

21-19N-9E