

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
yellow clay	0	18
yellow sandstone	18	37
gray sandstone	37	39
yellow sandstone	39	50
gray sandstone	50	52
gray shale	52	57

Total Depth

57

Casing: 5" PVC SDR 21 from -1' to 57'

Grout: BENTONITE from 3 to 27

Water from sandstone at 37' to 54'

Static level 20' below casing top which is 1' above GL

Pumping level 42' when pumping at 8 gpm for 1 hr(s)

Permanent pump installed at 48' on 10/2/1993, with a capacity of 8 gpm

Owner Address: R.R. #2, Martinsville, IL

Address of well: Co. Rd. #600N

Location source: Location from permit

Permit Date: September 13, 1993 Permit #: 023386

COMPANY Green, William E.

FARM Medsker, D.C.

DATE DRILLED October 2, 1993

NO. 1

ELEVATION 0'

COUNTY NO. 25943

LOCATION

LATITUDE 39.237929

LONGITUDE -87.750066

COUNTY Clark

API# 1202325943 00

17-9N-12W