

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	15
gray mud	15	20
dry mud & embedded gravel	20	25
gray mud	25	51
small gravel	51	56
gray mud	56	65
gray shale	65	73
sandrocks	73	76
sandy gray shale	76	110
coal	110	112
shale	112	225

Total Depth

225

Casing: 6" PVC from 0' to 69'

Grout: BENSEAL from 0 to 65

Water from coal at 110' to 112'

Static level 51' below casing top which is 2' above GL

Pumping level 200' when pumping at 7 gpm for 1 hr(s)

Permanent pump installed at 210' on 6/18/2000, with a capacity of 7 gpm

Remarks: driller's est. well yield 3 gpm

Owner Address: 4371 Hospital Rd. Terre Haute, IN

Address of well: 1300 East Rd. Clark Center, IL Clark Center IL

Location source: Location from permit

Permit Date: June 6, 2000

Permit #:

COMPANY Mumma Brothers Drilling, Inc.

FARM Mullin, Steve

DATE DRILLED June 10, 2000

NO. 1

ELEVATION 0'

COUNTY NO. 26667

LOCATION

LATITUDE 39.346589

LONGITUDE -87.770524

COUNTY Clark

API# 1202326667 00

6-10N-12W