

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
brown clay	0	18
sand & gravel	18	19
gray hardpan	19	34
gray sand	34	35
gray hardpan	35	45

Total Depth

45

Casing: 6" PVC SDR 21 from -1' to 15'
 30" CONCRETE from 15' to 45'

Grout: BENTONITE CHIPS from 10 to 11

Water from sand at 18' to 19'

Static level 6' below casing top which is 1' above GL

Pumping level ' when pumping at 3 gpm for 2 hr(s)

Owner Address: 18301 N 2420th St Marshall, IL

Address of well: same as above

Location source: Location from permit

Permit Date: September 13, 2010 **Permit #:** 023-07-2010

COMPANY Van Gilder, Richard E.

FARM Clark, Charles

DATE DRILLED September 17, 2010 **NO.** 2

ELEVATION ' **COUNTY NO.** 27128

LOCATION

LATITUDE 39.412569 **LONGITUDE** -87.574294

COUNTY Clark **API#** 1202327128 00 **12-11N-11W**