

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
yellow clay	0	21
yellow & gray clay	21	30
gray clay with gravel	30	33
green clay	33	39
gray clay with gravel	39	60
green clay	60	73
gray shale	73	118
sandy shale	118	130
gray shale	130	147
sandstone	147	155

Total Depth **155**

Casing: 5" SDR 21 from -2' to 80'

Grout: CTGS BENTONITE from 0 to 80

Water from sandstone at 147' to 155'

Static level 60' below casing top which is 2' above GL

Pumping level 130' when pumping at 5 gpm for 3 hr(s)

Permanent pump installed at 0' on , with a capacity of 0 gpm

Remarks: coliform >200.5,nitrate <10,EColi 7.5

Owner Address: P.O. Box #225 Edgewood, IL

Address of well: same as above

Location source: Location from permit

Permit Date: August 20, 1998

Permit #: 025-013-98

COMPANY Ready, Dale

FARM Yingst, Vic

DATE DRILLED August 23, 1998

NO. 1

ELEVATION 0'

COUNTY NO. 28522

LOCATION

LATITUDE 38.901863

LONGITUDE -88.580760

COUNTY Clay

API# 1202528522 00

1-5N-5E