

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
soil & yellow clay	0	8
sand & gravel	8	20
blue shale	20	26

Total Depth **26**

Casing: 5" PVC from -3' to 12'

3" PVC SCREEN from 12' to 20'

Screen: 8' of 5" diameter 90 slot

Grout: EZ SEAL from to

Water from sand & gravel at 12' to 20'

Static level 7' below casing top which is 3' above GL

Pumping level 13' when pumping at 3 gpm for 2 hr(s)

Permanent pump installed at ' on , with a capacity of gpm

Remarks: Driller's Estimated Well Yield 3 gpm

Owner Address: 5 Meadow Lane Mattoon, IL
Charleston, IL Charleston IL

Location source: Location from permit

Permit Date: March 2, 2009

Permit #: 029-001-08

COMPANY Baker, Donald K.

FARM Clausing, David

DATE DRILLED March 26, 2009

NO. 1

ELEVATION '

COUNTY NO. 24385

LOCATION

LATITUDE 39.422200

LONGITUDE -88.199067

COUNTY Coles

API# 1202924385 00

4-11N-9E