

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
sicl br mot trsa	0	16
sac1 mot	16	18
sicl gr trsa	18	54
sa gr fi	54	55
sicl gr sa	55	78

Total Depth

78

Casing: 30" CONCRETE from 13' to 78'
 6" SDR 21 from -12' to 13'

Grout: BENTONITE from 12 to 13

Water from sand at 54' to 55'

Static level 54' below casing top which is 1' above GL

Remarks: Driller's Estimated Well Yield 2 gpm

Owner Address: 6563 Snaketraill Rd Charleston, IL

Address of well: same as above

Location source: Global Positioning System verified

Permit Date: July 1, 2022

Permit #: 029-004-22

COMPANY Gaza, John Edward

FARM Beeman, Josh

DATE DRILLED February 22, 2023

NO.

ELEVATION '

COUNTY NO. 24451

LOCATION

LATITUDE 39.783889

LONGITUDE -88.168333

COUNTY Coles

API# 1202924451 00

20-12N-9E