

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
overburden	0	126
rock formation	126	205
Silurian	126	

Total Depth **205**

Casing: 5" BLACK 15# from 0' to 126'

Size hole below casing: 5"

Water from limestone at 80' to 205'

Static level 80' below casing top which is 2' above GL

Pumping level 105' when pumping at 50 gpm for 40 hr(s)

Permanent pump installed at ' on , with a capacity of gpm

Owner Address: 131st St. & Wolf Rd. Palos Park, IL

Location source: Location from permit

Verified by: VJA on 6/25/2018

Permit Date: April 18, 1973

Permit #: 22715

COMPANY Knierum, Paul

FARM Beursken, Thomas

DATE DRILLED October 23, 1973

NO.

ELEVATION 716' GL

COUNTY NO. 04518

LOCATION

LATITUDE 41.648832

LONGITUDE -87.886812

COUNTY Cook

API# 1203104518 00

32-37N-12E