

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
black dirt	0	5
yellow clay	5	17
gravel	17	31
blue clay	31	77
boulders	77	92
bouldery gravel	92	111
boulders	111	126
soapstone	126	152
rock	152	200

Total Depth **200**

Casing: 5" A-53 GALV from 0' to 152'

Size hole below casing: 4.75"

Water from rock at 152' to 200'

Static level 80' below casing top which is 1' above GL

Pumping level 120' when pumping at 20 gpm for 4 hr(s)

Permanent pump installed at 120' on 12/17/1979, with a capacity of 15 gpm

Owner Address: 12505 S. 81st Ave. Palos Park, IL

Location source: Aerial Photograph verified

Verified by: VJA on 6/11/2018

Permit Date: December 21, 1979 **Permit #:** 92151

COMPANY Foyle, Richard S.

FARM Graninger, Mildred B.

DATE DRILLED December 17, 1979 **NO.**

ELEVATION 0' **COUNTY NO.** 29391

LOCATION

LATITUDE 41.663454 **LONGITUDE** -87.817876

COUNTY Cook **API#** 1203129391 00 **26-37N-12E**