

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
brown clay	0	10
sand & clay	10	50
sand	50	80
gravel	80	106
shelf & grey clay	106	122
limestone	122	158

Total Depth **158**

Casing: 5" GALV 15# from 0' to 122'

Water from limestone at 122' to 158'

Static level 80' below casing top which is 1' above GL

Pumping level 120' when pumping at 15 gpm for 3 hr(s)

Permanent pump installed at 124' on 1/23/1981, with a capacity of 12 gpm

Remarks:

Owner Address: 306 N. Pine St. Prospect Heights, IL

Address of well:

Add'l loc info: Lot: 1 Subdivision: Schuld's
Smith & Dawson's Cnty Clb

Location source: Location from permit

Verified by: VJA on 6/10/2025

Permit Date: December 19, 1980 **Permit #:** 97932

COMPANY Szymanski, Mitchell

FARM Kirste, Donald

DATE DRILLED January 17, 1981 **NO.** 1

ELEVATION 0' **COUNTY NO.** 29605

LOCATION

LATITUDE 42.098082 **LONGITUDE** -87.942799

COUNTY Cook **API#** 1203129605 00 **22-42N-11E**