

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
surface & clay	0	50
sand & gravel	50	109
limestone	109	160
Silurian	109	
Total Depth	160	

Casing: 5" BLACK STEEL from 0' to 109'

Grout: CUTTINGS from 0 to 109

Size hole below casing: 5"

Water from limestone at 0' to 0'

Static level 60' below casing top which is 1' above GL

Pumping level 80' when pumping at 10 gpm for 4 hr(s)

Permanent pump installed at 80' on , with a capacity of 10 gpm

Remarks: owner to take sample

Owner Address: 13800 Kenton Ave. Crestwood, IL

Add'l loc info: Lot: 4 Subdivision: Zimmerman's

Location source: Aerial Photograph verified

Verified by: VJA on 6/18/2018

Permit Date: May 31, 1984

Permit #: 112610

COMPANY Rob, Peter

FARM McNaughton Builders

DATE DRILLED May 31, 1984

NO.

ELEVATION 706' GL

COUNTY NO. 29780

LOCATION

LATITUDE 41.660427

LONGITUDE -87.836341

COUNTY Cook

API# 1203129780 00

27-37N-12E