

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
brown clay	0	92
sand & gravel	92	100
brown clay	100	124
gravel	124	153
white limestone	153	260

Total Depth **260**

Casing: 5" STEEL ASTM A53B from 0' to 157'

Grout: BENTONITE from 0 to 157

Water from white limestone at 157' to 260'

Static level 70' below casing top which is 2' above GL

Pumping level 180' when pumping at 15 gpm for 2 hr(s)

Permanent pump installed at 180' on 1/18/2007, with a capacity of 15 gpm

Remarks: Driller's Estimated Well Yield 15 gpm

Owner Address: 15541 118th Ave. Orland Park, IL

Address of well: 15810 S. 113th Ave. Orland Park, IL Orland Park IL

Add'l loc info: Lot: 112 Subdivision: Delugachs Wooded Est

Location source: Aerial Photograph verified

Verified by: VJA on 8/13/2015

Permit Date: January 25, 2006

Permit #: 031-00014-06

COMPANY Senffner, Keith

FARM F & B Builders

DATE DRILLED January 3, 2007

NO.

ELEVATION '

COUNTY NO. 35058

LOCATION

LATITUDE 41.601885

LONGITUDE -87.894074

COUNTY Cook

API# 1203135058 00

18-36N-12E