

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
yellow clay	0	7
gray clay with gravel streaks	7	35
clay	35	45
gravel & sand	45	54
broken rock	54	55
limestone	55	130

Total Depth **130**

Casing: 6" STEEL from ' to '

Grout: BENTONITE from 1 to 55

Water from limestone at 81' to 130'

Static level 13' below casing top which is 3' above GL

Pumping level 17' when pumping at 240 gpm for 24 hr(s)

Permanent pump installed at ' on , with a capacity of gpm

Owner Address: 3345 Butler South Chicago, IL

Address of well: 21751 Jason Rasmussen Dr. Sauk Village, IL Sauk Village IL

Location source: Global Positioning System verified

Verified by: VJA on 1/26/2017

Permit Date: July 8, 2011

Permit #: 031-011-11

COMPANY Liberg, Steven Scott

FARM Winpak Portion Packaging

DATE DRILLED September 17, 2011

NO.

ELEVATION '

COUNTY NO. 36019

LOCATION

LATITUDE 41.495598

LONGITUDE -87.591187

COUNTY Cook

API# 1203136019 00

26-35N-14E