

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil	0	1
silty clay fill	1	2
silurian dolomite	2	202

Total Depth

202

Casing: 2" SS SCREEN from 192' to 202'

2" SS from 7' to 192'

2" SCH 40 PVC from 0' to 7'

6" STEEL from 0' to 29'

Screen: 10' of 2" diameter 0.01 slot

Grout: BENTONITE CHIPS from 4 to 28

PORTLAND CEMENT from 28 to 175

BENT PELLETS from 175 to 187

Water from silurian dolomite at 189' to 202'

Static level 19' below casing top which is 0' above GL

Address of well: 4100 Frontage Road Hillside, IL 60162 Hillside IL

Location source: Global Positioning System verified

Verified by: VJA on 2/12/2024

Permit Date:

Permit #:

COMPANY Raimonde & Sons

FARM Congress Development Company

DATE DRILLED October 18, 2013

NO. A-46D

ELEVATION 663' GL

COUNTY NO. 36504

LOCATION

LATITUDE 41.875203

LONGITUDE -87.892625

COUNTY Cook

API# 1203136504 00

17-39N-12E