

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
black dirt	0	3
brown clay	3	15
blue clay	15	94
gravel	94	96
limestone	96	120

Total Depth **120**

Casing: 5" PVC CERTILOCK from -1' to 78'

5" A53B GALV from 74' to 96'

4" A53B GALV from 94' to 98'

Grout: BEN from 0 to 86

Water from limestone at 96' to 120'

Static level 60' below casing top which is 1' above GL

Pumping level 60' when pumping at 15 gpm for 1 hr(s)

Permanent pump installed at 108' on , with a capacity of 10 gpm

Remarks: Driller's Estimated Well Yield 20+ gpm

Owner Address: 8 Drake Terrace Prospect Heights, IL

Address of well: same as above

Location source: Global Positioning System verified

Verified by: VJA on 3/20/2023

Permit Date: June 30, 2022

Permit #: 031-082-2022

COMPANY Schwall, John J.

FARM Kupon, Robert

DATE DRILLED August 15, 2022

NO.

ELEVATION '

COUNTY NO. 52124

LOCATION

LATITUDE 42.119583

LONGITUDE -87.935317

COUNTY Cook

API# 1203152124 00

15-42N-11E