

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	125
limestone	125	500

Total Depth 500

Casing: 6" PVC GLUE SDR 21 from -2' to 125'

Grout: BENTONITE from 0 to 125

Water from limestone at 200' to 500'

Static level 15' below casing top which is 2' above GL

Pumping level 300' when pumping at 35 gpm for 4 hr(s)

Permanent pump installed at 460' on 11/23/2023, with a capacity of 35 gpm

Remarks: Driller's Estimated Well Yield 40 gpm

Owner Address: 7931 W 143rd St Orland Park, IL

Address of well: same as above

Location source: Aerial Photograph verified

Verified by: VJA on 6/1/2024

Permit Date: May 1, 2023

Permit #: 031-022-23

COMPANY Will County Well & Pump

FARM Sulikowski, Jan

DATE DRILLED August 10, 2023

NO.

ELEVATION '

COUNTY NO. 53381

LOCATION

LATITUDE 41.628929

LONGITUDE -87.813358

COUNTY Cook

API# 1203153381 00

12-36N-12E