

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	15
clay w/ gravel	15	54
soft rock w/ shale	54	60
limestone	60	280
gray rock	280	300

Total Depth **300**

Casing: 6" PVC CEMENTED from 0' to 64'

Grout: ENVORPLUG from 0 to 62

Water from limestone at 80' to 280'

Static level 60' below casing top which is 1' above GL

Pumping level 100' when pumping at 20 gpm for 1 hr(s)

Permanent pump installed at 140' on 1/10/2024, with a capacity of 20 gpm

Remarks: Driller's Estimated Well Yield 30 gpm

Owner Address: 17954 S Crystal Lake Dr Mokena, IL

Address of well: 52 Brookside Dr Lemont, IL Lemont IL

Location source: Aerial Photograph verified

Verified by: VJA on 6/1/2024

Permit Date: November 29, 2022 **Permit #:** 031-149-22

COMPANY Stinnett, David

FARM Burdleck Builders

DATE DRILLED November 20, 2023 **NO.**

ELEVATION ' **COUNTY NO.** 53386

LOCATION

LATITUDE 41.683286 **LONGITUDE** -87.922193

COUNTY Cook **API#** 1203153386 00 **24-37N-11E**