

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	65
fine sand	65	70
clay & stones	70	85
limestone	85	160

Total Depth **160**

Casing: 5" ASTM A53B STEEL from -1' to 86'

Grout: GRANULAR BENTONITE from to

Water from limestone at 85' to 160'

Static level 30' below casing top which is 1' above GL

Pumping level 60' when pumping at 15 gpm for 2 hr(s)

Permanent pump installed at 83' on 9/6/2007, with a capacity of 10 gpm

Remarks: Driller's Estimated Well Yield 15 gpm

Owner Address: 212 Hortense Dr. Kirkland, IL

Address of well: 32338 White St Fairdale, IL Fairdale IL

Location source: Aerial Photograph verified

Verified by: VJA on 11/9/2021

Permit Date: September 21, 2007 **Permit #:** 037-11275-07

COMPANY Stone, Guy D.

FARM Kamp, Gerald

DATE DRILLED August 28, 2007

NO.

ELEVATION

COUNTY NO. 23593

LOCATION

LATITUDE 42.099053

LONGITUDE -88.931070

COUNTY DeKalb

API# 1203723593 00

19-42N-3E