

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay & stones	0	115
sand & gravel	115	125
limestone & shale	125	143
limestone	143	285

Total Depth **285**

Casing: 6" STEEL THREADED from -2' to 145'

Grout: PRESSURE from 0 to 145

Water from limestone at 143' to 285'

Static level 40' below casing top which is 2' above GL

Pumping level 80' when pumping at 15 gpm for 2 hr(s)

Permanent pump installed at 120' on 9/15/2022, with a capacity of 15 gpm

Remarks: Driller's Estimated Well Yield 15 gpm

Owner Address: 14775 Keslinger Rd DeKalb, IL

Address of well: same as above

Location source: Global Positioning System verified

Permit Date: August 24, 2022

Permit #: 037-2243-22

COMPANY Stone, Bradley W.

FARM Johnson, Creedence

DATE DRILLED September 15, 2022

NO.

ELEVATION '

COUNTY NO. 23975

LOCATION

LATITUDE 41.879944

LONGITUDE -88.664944

COUNTY DeKalb

API# 1203723975 00

4-39N-5E