

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
soil	0	1
clay	1	76
sand & gravel	76	84
sand	84	104
sand & gravel	104	118
limestone	118	130

Total Depth **130**

Casing: 5" 15# SEAMLESS from 0' to 118'

Size hole below casing: 5"

Water from limestone at 0' to 0'

Static level 47' below casing top which is 8' above GL

Pumping level 47' when pumping at 10 gpm for 0 hr(s)

Permanent pump installed at ' on , with a capacity of gpm

Driller's Log filed.

Permit Date:

Permit #:

COMPANY Neely & Son

FARM Chateau Homes

DATE DRILLED May 1, 1967

NO.

ELEVATION 0'

COUNTY NO. 00838

LOCATION

LATITUDE 41.890103

LONGITUDE -88.145829

COUNTY DuPage

API# 1204300838 00

6-39N-10E