

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
soil	0	2
clay	2	62
sand & gravel	62	74
clay	74	94
sand & gravel	94	118
limestone	118	123

Total Depth **123**

Casing: 5" 15# SEAMLESS from 0' to 118'

Size hole below casing: 5"

Water from limestone at 0' to 0'

Static level 47' below casing top which is 8' above GL

Pumping level 47' when pumping at 10 gpm for 0 hr(s)

Permanent pump installed at ' on , with a capacity of gpm

Driller's Log filed.

Permit Date:

Permit #:

COMPANY Neely & Son

FARM Chateau Homes

DATE DRILLED May 1, 1967

NO.

ELEVATION 740.236022949219'
DM

COUNTY NO. 00839

LOCATION

LATITUDE 41.890103

LONGITUDE -88.145829

COUNTY DuPage

API# 1204300839 00

6-39N-10E