

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	25
s & g	25	90
limestone	90	170

Total Depth **170**

Casing: 5" BLACK STEEL from 0' to 90'

Grout: CUTTINGS from 0 to 90

Size hole below casing: 5"

Water from limestone at 0' to 0'

Static level 60' below casing top which is 1' above GL

Pumping level 100' when pumping at 10 gpm for 4 hr(s)

Permanent pump installed at 0' on , with a capacity of 10 gpm

Owner Address: 5120 Belmont Rd. Suite Y Downers Grove, IL

Add'l loc info: Lot: 37 Subdivision: Woods of Cantigny
Unit 3

Location source: Field verified

Permit Date: February 4, 1987 **Permit #:** 129312

COMPANY Rob, Ronald

FARM Energy Craft Homes

DATE DRILLED February 14, 1987 **NO.**

ELEVATION 0' **COUNTY NO.** 27679

LOCATION 1800'S line, 2450'W line of

LATITUDE 41.847274 **LONGITUDE** -88.176496

COUNTY DuPage **API#** 1204327679 00 **23-39N-9E**