

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	65
sand & gravel	65	130
rock	130	180
shale at	180	180

Total Depth **180**

Casing: 5" PVC from 0' to 130'

Size hole below casing: 5"

Water from limestone at 130' to 180'

Static level 40' below casing top which is 1' above GL

Pumping level 40' when pumping at 10 gpm for 2 hr(s)

Permanent pump installed at 180' on 6/5/1990, with a capacity of 30 gpm

Owner Address: 1094 Spring Valley Dr. Carol Stream, IL

Address of well: 27W761 Timber Lane West Chicago, IL West Chicago
IL

Add'l loc info: Lot: #52 Subdivision: Wayne Oaks

Location source: Location from permit

Permit Date: April 12, 1990

Permit #: 017527

COMPANY Liberg, John E.

FARM Colliander, Ron

DATE DRILLED May 18, 1990

NO.

ELEVATION 758.209411621094'
DM

COUNTY NO. 28927

LOCATION

LATITUDE 41.917841

LONGITUDE -88.164030

COUNTY DuPage

API# 1204328927 00

25-40N-9E