

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	10
sand & gravel	10	55
stoney clay	55	75
gravel	75	91
limestone	91	160

Total Depth **160**

Casing: 5" PVC SCHEDULE 80 from 0' to 94'

Grout: BENTONITE SLRY from 0 to 94

Size hole below casing: 5"

Water from limestone at 94' to 160'

Static level 50' below casing top which is 1' above GL

Pumping level 50' when pumping at 0 gpm for 2 hr(s)

Permanent pump installed at 120' on 2/15/1994, with a capacity of 100 gpm

Owner Address: 27W 760 Parkview Warrenville, IL

Address of well: 27W 465 Wallace Rd. Wheaton, IL Wheaton IL

Add'l loc info: Lot: #14 Subdivision: Twin Oak

Location source: Location from permit

Permit Date: July 4, 1993

Permit #: 93-1985

COMPANY Charles M. Kerry

FARM Papaelion, Lewis

DATE DRILLED January 25, 1994

NO.

ELEVATION 709.336608886719'
DM

COUNTY NO. 29449

LOCATION

LATITUDE 41.839754

LONGITUDE -88.159787

COUNTY DuPage

API# 1204329449 00

25-39N-9E