

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	50
stoney clay	50	108
sand & gravel	108	116
limestone	116	180

Total Depth **180**

Casing: 5" PVC SCHEDULE 80 from 0' to 120'

Grout: BENTONITE SLRY from 0 to 120

Size hole below casing: 5"

Water from limestone at 120' to 180'

Static level 50' below casing top which is 1' above GL

Pumping level 50' when pumping at 0 gpm for 2 hr(s)

Permanent pump installed at 80' on 2/18/1994, with a capacity of 50 gpm

Remarks: Old well sealed 2/18/94.

Owner Address: 0N 720 Barry Ave. Wheaton, IL

Add'l loc info: Lot: #26 Subdivision: Pleasant Hill Manor
Unit #1

Location source: Location from permit

Permit Date: February 2, 1994 **Permit #:** H940023

COMPANY Charles M. Kerry

FARM Vashey, Denise & Carol

DATE DRILLED February 18, 1994 **NO.**

ELEVATION 753.932922363281' **COUNTY NO.** 29473
DM

LOCATION

LATITUDE 41.885660 **LONGITUDE** -88.144608

COUNTY DuPage **API#** 1204329473 00 **7-39N-10E**