

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay tan	0	96
broken rock	96	112
limestone	112	140

Total Depth **140**

Casing: 6" STEEL A53B from -2' to 112'

Grout: BENTONITE GRANULES from 0 to 112

Water from limestone at 112' to 140'

Static level 49' below casing top which is 2' above GL

Pumping level 49' when pumping at 22 gpm for 4 hr(s)

Permanent pump installed at 100' on 11/15/2006, with a capacity of 22 gpm

Remarks: Driller's Estimated Well Yield 60+ gpm

Owner Address: 26W416 Grand Ave. Wheaton, IL

Address of well: same as above

Add'l loc info: Lot: 15 Subdivision: Pleasant Hill Manor
Unit 1

Location source: Location from permit

Permit Date: October 5, 2006 **Permit #:** H060169

COMPANY Steve Liberg, Jr.

FARM Hometown Builders/Jaime Ozman

DATE DRILLED November 15, 2006 **NO.**

ELEVATION ' **COUNTY NO.** 31667

LOCATION

LATITUDE 41.883833 **LONGITUDE** -88.141833

COUNTY DuPage **API#** 1204331667 00 **7-39N-10E**