

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	109
gravel	109	115
solid limestone	115	117
broken limestone	117	120

Total Depth **120**

Casing: 5" PVC from -1' to 117'

Grout: VOLCLAY GROUT from 0 to 60

Water from limestone at 117' to 120'

Static level 44' below casing top which is 1' above GL

Pumping level 45' when pumping at 10 gpm for 1 hr(s)

Permanent pump installed at 80' on 4/24/2009, with a capacity of 10 gpm

Remarks: Driller's Estimated Well Yield 40 gpm

Owner Address: 6N680 Gates Ave Itasca, IL

Address of well: 6N524 Irving Park Rd Itasca, IL Itasca IL

Add'l loc info: Lot: 9-12 Subdivision: Percy Wilson's CC

Location source: Location from permit

Permit Date: September 16, 2008 **Permit #:** 043-H080103-09

COMPANY Efflandt, Robert

FARM Skora, Marzena

DATE DRILLED April 23, 2009

NO.

ELEVATION '

COUNTY NO. 31860

LOCATION

LATITUDE 41.975633

LONGITUDE -88.044767

COUNTY DuPage

API# 1204331860 00

12-40N-10E