

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil	0	3
brown clay	3	10
gray hardpan	10	20
gray sand	20	24
gray hardpan	24	61
soft gray hardpan	61	66
gray hardpan	66	105
gray sand & gravel	105	112
gray hardpan	112	120

Total Depth **120**

Casing: 5" PVC from 0' to 115'

Screen: 5' of 5" diameter 25 slot

Grout: BENSEAL from 6 to 65

Water from sand & gravel at 105' to 112'

Static level 24' below casing top which is 2' above GL

Pumping level 0' when pumping at 5 gpm for 10 hr(s)

Owner Address: 19648 E 2256 Chrisman, IL

Address of well: same as above

Add'l loc info: Subdivision: Scotland Village

Location source: Location from permit

Permit Date: July 3, 2002

Permit #:

COMPANY Erwin, Harold E.

FARM Barker, Lodell

DATE DRILLED July 29, 2002

NO.

ELEVATION 0'

COUNTY NO. 23236

LOCATION

LATITUDE 39.803343

LONGITUDE -87.604799

COUNTY Edgar

API# 1204523236 00

26-16N-11W